



Product Service

CERTIFICATE

No. Z2 114228 0033 Rev. 04

OYUNG CORPORATION

Xiangbinzhiyue Park, Gongshu District
Hangzhou City, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062302133-39

Valid until: 2029-06-06

Date, 2024-06-07

(Zhulin Zhang)

CERTIFICATE

No. Z2 114228 0033 Rev. 04

Model(s):

OSM78NTB xxx, xxx = 625 to 650 in steps of 5
OSM72NTB xxx, xxx = 570 to 600 in steps of 5
OSM72NTM xxx, xxx = 580 to 605 in steps of 5
OSM66NTB xxx, xxx = 605 to 630 in steps of 5
OSM66NTM xxx, xxx = 610 to 635 in steps of 5
OSM60NTM xxx, xxx = 475 to 500 in steps of 5
OSM54NTM xxx, xxx = 435 to 460 in steps of 5
OSM54NTB xxx FB, xxx = 425 to 450 in steps of 5
OSM54NTM xxx FB, xxx = 430 to 455 in steps of 5
xxx is standing for rated output power at STC

Parameters:

| | |
|---------------------------|--|
| Construction: | Framed, with Junction box, Cable and Connectors. |
| Test Laboratory: | Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China |
| Safety Class: | Class II |
| Maximum System Voltage: | 1500 V DC |
| Fire Safety Class: | Class C according to UL790 |
| Production Facility(ies): | 079395, 095903, 108746, 072092, 109998, 112017, 113943, 114922, 004170, 121678, 123101, 123430, 119123, 126010, 121158. |

Tested according to:

IEC 61215-1:2021
EN IEC 61215-1:2021/AC:2021
IEC 61215-1-1:2021
EN IEC 61215-1-1:2021
IEC 61215-2:2021
EN IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023